



**STANDALONE CONTROL STREETLIGHT PILLAR**  
(FRONT VIEW)  
NOT TO SCALE

**NOTES:**

1. THIS INSTALLATION ARRANGEMENT IS FOR NEW SUBDIVISION DESIGN, A STREETLIGHT CONTROL IS FITTED IN A STANDALONE 3 SLOT PILLAR, INSIDE AN INDEPENDANT 1m x 1m EASEMENT OR ROAD ALLOCATION.
2. ALL CABLES SHALL HAVE DESTINATION TAGS.
3. FOR P.E. CONTROLLED STREET LIGHTS REMOVE THE TIMECLOCK AND CONTACTOR.

MATERIAL SCHEDULE		
ITEM No.	QTY.	DESCRIPTION
1	1	3 SLOT STRIPPLE FUSE PILLAR
2	AR	25 mm <sup>2</sup> XLPE /NJ/PVC
3	1	TIME CONTROL PACK
4	1	SUPPORT PANEL - TIME CONTROL PACK
5	AR	63A LV CIRCUIT BREAKER 3 PHASE
6	AR	20 amp SINGLE POLE MCBS OR 3 POLE AS REQUIRED
7	AR	TIME CLOCK
8	AR	3 POLE CONTACTOR AS REQUIRED

0	ISSUED AS A STANDARD DRAWING	SEP 2025	N.V.	DLI	
No.	DESCRIPTION	DATE	NAME	DEPT/COMPANY	
	AMENDMENTS				

**WARNING**  
BEWARE OF UNDERGROUND SERVICES.  
THE LOCATIONS OF UNDERGROUND SERVICES ARE APPROXIMATE ONLY AND THEIR EXACT POSITION SHOULD BE PROVEN ON SITE. NO GUARANTEE IS GIVEN THAT ALL EXISTING SERVICES ARE SHOWN.

DRAWN PWC	CHECKED T.Berrill
DATE	DATE
DESIGNED PWC	CHECKED T.Berrill
DATE	DATE
DESIGN LEADER	DESIGN DIRECTOR
DATE	DATE



STANDARD DRAWINGS STREETLIGHTING ELECTRICAL					
<b>STREETLIGHT CONTROL PANEL STANDALONE ARRANGEMENT DISTRIBUTION PILLAR MOUNTING</b>					
FILE No.	ASSET No.	SHEET No.	DRAWING No.	AMEND.	SHEET SIZE
-	-	1 OF 1	CS3903	0	A1