

# NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES - STRUCTURAL REQUIREMENTS

## Contents

1	General requirements .....	2
1.1	Structural design.....	2
1.2	Definition .....	2
1.3	Proprietary truss.....	2
1.4	Timber products .....	3
1.5	Safety in design (SID).....	3
1.6	Maintainability.....	3
1.7	Construction phase shop drawings and requests for information (RFIs).....	3
2	Standards .....	3
3	Design drawings .....	4
4	Design deliverables.....	5
5	Additional design requirements .....	9
5.1	General design requirements .....	9
5.1.1	Design engineer.....	9
5.1.2	Design life .....	10
5.1.3	Building importance levels .....	10
5.1.4	Structural robustness.....	11
5.1.5	Deflection limits .....	11
5.1.6	Non-structural parts and components .....	12
5.1.7	Modification to existing structure .....	12
5.1.8	Ecological sustainable design (ESD).....	12
5.2	Design loads .....	12
5.2.1	Dead and live loads.....	12
5.2.2	Wind loads .....	12
5.2.3	Earthquake loads.....	13
6	Geotechnical investigation.....	13
6.1	Foundation design .....	13
6.2	Earth pressure .....	13
7	Building fabric and layout .....	14
7.1	Location of walls, columns and wall bracing .....	14
7.2	Fire resistance .....	14

NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND  
REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES -  
STRUCTURAL REQUIREMENTS

7.3	Strength .....	14
7.4	Stability .....	14
7.5	Serviceability .....	14
7.6	Waterproofing and weatherproofing .....	15
8	Concrete and masonry .....	15
8.1	Concrete durability .....	15
8.2	Crack control .....	15
8.3	Post tensioned or precast concrete slab .....	15
8.4	Ground slab moisture barrier and bedding sand .....	16
8.5	External slab .....	16
8.6	Slab joints .....	16
8.7	Masonry .....	16
9	Steel and metal .....	17
9.1	Protective coatings on steel .....	17
9.2	Dissimilar metals .....	19
9.3	Steel stud wall frame .....	19
9.4	Metal capping and flashing .....	19
9.5	Metal roof and wall sheeting .....	19
9.6	Hold-down anchor .....	19

## 1 General requirements

### 1.1 Structural design

Structural engineering design of the building work is to comply with the relevant requirements of the current National Construction Code (NCC), the *NT Building Act 1993*, the *Work Health and Safety (National Uniform Legislation) Act 2011*, all current relevant Australian Standards and other statutory requirements.

### 1.2 Definition

For the purpose of this document, the word 'shall' indicates that a statement is mandatory.

### 1.3 Proprietary truss

Do not use light gauge cold formed "C" channel sections for trusses.

Do not specify or use manufacturer prefabricated steel or timber trusses for non-domestic buildings.

NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES - STRUCTURAL REQUIREMENTS

## 1.4 Timber products

Do not use timber material for any part of the structural work without approval.

## 1.5 Safety in design (SID)

Comply with the *Work Health and Safety (National Uniform Legislation) Act 2011*.

The design shall consider and incorporate design solutions that minimise the potential for danger during construction as well as during occupation and maintenance.

A SID report detailing the optimal solutions to minimise hazards and risk issues must be provided as part of the documentation work at the conclusion of the design project. Refer to s.22 of the Act, to Regulation 295, and to the NT Code of Practice *Safe design of structures*.

## 1.6 Maintainability

Any part of the building, or a building element where maintenance needs to be undertaken, shall be provided with suitable access to enable works to be safely undertaken and to meet the requirements of the *WHS (NUL) Act 2011* and the *WHS Regulations*.

## 1.7 Construction phase shop drawings and requests for information (RFIs)

The Engineer engaged for the structural design is required to review Shop Drawings (precast concrete and/or steelwork) to ensure the intent of the design has been correctly interpreted. The review should include general arrangement, member sizes and connection details, but should not be regarded as a check of dimensions. In addition, the Design Engineer is also responsible for responding to any Request for Information (RFIs) during construction.

## 2 Standards

The following standards shall be used as a minimum in the design of the building structure.

Table – Australian Standards	
Use Standards, and their amendments, current as at the date for the close of tenders except where different editions and/or amendments are required by statutory authorities, including, but not limited to, NATA and the National Construction Code including the Building Code of Australia.	
Designation	Title
AS 1170 (series)	- Structural design actions
AS/NZS 1170.0	- General Principles

NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND  
REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES -  
STRUCTURAL REQUIREMENTS

<b>Table – Australian Standards</b>	
Use Standards, and their amendments, current as at the date for the close of tenders except where different editions and/or amendments are required by statutory authorities, including, but not limited to, NATA and the National Construction Code including the Building Code of Australia.	
<b>Designation</b>	<b>Title</b>
AS/NZS 1170.1	- Permanent, imposed and other actions
AS/NZS 1170.2	- Wind actions
AS 1170.4	- Earthquake actions in Australia
AS 1562 (series)	Design and installation of sheet roof and wall cladding
AS 1562.1	- Metal
AS 1657	Fixed platforms, stairways, walkways and ladders
AS 2047	Windows and external glazed doors in buildings
AS 2159	Piling – Design and installation
AS 2312 (series)	Guide to the protection of structural steel
AS 2312.1	- Paint coatings
AS 2312.2	- Hot-dip galvanising
AS 2870	Residential slabs and footings
AS 3600	Concrete structures
AS 3700	Masonry structures
AS 3798	Guidelines on earthworks for commercial and residential developments
AS 3850	Tilt-up concrete construction
AS 4100	Steel structures
AS 4600	Cold formed steel structures
AS 4678	Earth retaining structures
AS/NZS 4680	Hot-dip galvanized (zinc) coatings on fabricated ferrous articles
AS/NZS 4792	Hot-dip galvanized (zinc) coatings on ferrous hollow sections, applied by a continuous or a specialised process
AS 5131	Structural steelwork - Fabrication and erection

The above are the minimum standards that should be considered. All other relevant standards and codes must be adopted as deemed necessary.

### 3 Design drawings

The drawings shall comply with the following principles/requirements.

The drawings shall comply with NTG Technical Drawings Part 1 and Part 3.

Ensure there is no conflict between the Structural drawings and other discipline drawings.

Depicting structural details on other discipline drawings is not acceptable.

# NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES - STRUCTURAL REQUIREMENTS

Incomplete structural documentation is not acceptable.

Structural notes should not be excessive with only the notes that are relevant to be shown. Notes that are not relevant shall not be included.

All graphical details shall be drawn to the correct scales. The outlines and details of a representation should be proportional to the represented part.

Details shall be unambiguous and clear. For any feature of a drawing, there shall be only one interpretation. It must be easy for people who will read and use the drawings to understand the drawings. Details by description without actual graphical illustration is not acceptable.

Details of a specific nature and particular to an individual project need to be fully detailed in the drawings. It is important to ensure that the coverage is comprehensive. If a specific detail is required that is not similar to any other previously shown detail, it must be shown.

Details of specific nature based on standardised details are not acceptable. The details shall be purposely drawn to reflect and illustrate the detail envisaged.

Details shall be clearly cross-referenced to the appropriate design layout/elevation/section. Poor or erroneous cross-referencing is not acceptable. Omission of cross referencing is not acceptable.

Details not relevant or applicable to the project shall not be included as part of the detailing.

Areas of floor designed to support specific localised heavy loads (e.g. mechanical equipment or compactus storage) shall be noted and highlighted on the structural floor plans.

Amendments when required on drawings should be shown clouded and tagged with an appropriate mark in accordance with NTG Technical Drawings Part 1. Additionally, the amendment table within the title block of the drawing should be updated (with a brief description) to reflect the amendment.

## 4 Design deliverables

Drawing submittals for design review at each of the major phases shall meet the level of completion listed below.

NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND  
REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES -  
STRUCTURAL REQUIREMENTS

<b>Table – Design deliverables</b>					
<b>Deliverables (But not limited to)</b>	<b>25% Conceptual design and drawings established</b>	<b>50% Major design elements completed and design analysis completed</b>	<b>75% Detailed drawings and technical specification developing</b>	<b>95% Deliverables substantially complete</b>	<b>100% Contract document ready</b>
General structural notes, site plan, drawing index	Preliminary design criteria and parameters established	Address comments from previous review  Preliminary project specific structural notes presented	Address comments from previous reviews  Project specific structural notes finalised	Address comments from previous reviews  Amend as required	Complete
Ground slabs, column, wall, and footing layout plans, and related details	Preliminary layout plans and schedule showing slabs and footing information	Address comments from previous review  Layout plans, legend, and schedule (showing type, size and reinforcement) confirmed and presented  Preliminary details presented	Address comments from previous reviews  Layout plans and related details complete	Address comments from previous reviews  Amend as required	Complete

NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES - STRUCTURAL REQUIREMENTS

<b>Table – Design deliverables</b>					
<b>Deliverables (But not limited to)</b>	<b>25% Conceptual design and drawings established</b>	<b>50% Major design elements completed and design analysis completed</b>	<b>75% Detailed drawings and technical specification developing</b>	<b>95% Deliverables substantially complete</b>	<b>100% Contract document ready</b>
Wall elevations and related details	Preliminary elevations showing design intent and type of construction	Address comments from previous review  Elevations with schedules showing steel member or reinforcement sizes  Preliminary details presented	Address comments from previous reviews  Elevations with schedules complete  Details developing and at an advanced stage	Address comments from previous reviews  Elevations and related details complete	Address comments from previous reviews  Complete
Sections and related details	Preliminary sections showing design intent	Address comments from previous review  Sections and related details developing and presented	Address comments from previous reviews  Sections and related details progressing and at an advanced stage	Address comments from previous reviews  Section and related details complete	Address comments from previous reviews  Complete

NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND  
REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES -  
STRUCTURAL REQUIREMENTS

<b>Table – Design deliverables</b>					
<b>Deliverables (But not limited to)</b>	<b>25% Conceptual design and drawings established</b>	<b>50% Major design elements completed and design analysis completed</b>	<b>75% Detailed drawings and technical specification developing</b>	<b>95% Deliverables substantially complete</b>	<b>100% Contract document ready</b>
Concrete beam, column, suspended slab layout, stairs, lift shaft plans, and related details if applicable	Preliminary layout plan showing design intent and approximate member sizes	Address comments from previous review  Plans and schedules (showing type, size and reinforcement) confirmed, including positive and negative reinforcement plans	Address comments from previous reviews  Plans and schedule complete  Details progressing and at an advanced stage	Address comments from previous reviews  All concrete elements and associated details complete	Address comments from previous reviews  Complete
Steel/concrete column and roof framing layout plans and related details	Preliminary concept showing design intent, layout plans and approximate member sizes	Address comments from previous review  Column layouts, roof framing layout plans, member schedules (with steel sizes) confirmed and presented  Developing steel connection detail details	Address comments from previous reviews  Framing layout plans, and member sizes complete  Steel connection details progressing and at an advanced stage	Address comments from previous reviews  All steelworks and associated details complete	Address comments from previous reviews  Complete



NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND  
REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES -  
STRUCTURAL REQUIREMENTS

<b>Table – Design deliverables</b>					
<b>Deliverables (But not limited to)</b>	<b>25% Conceptual design and drawings established</b>	<b>50% Major design elements completed and design analysis completed</b>	<b>75% Detailed drawings and technical specification developing</b>	<b>95% Deliverables substantially complete</b>	<b>100% Contract document ready</b>
Miscellaneous structures/items and/or details (e.g. walkways, stringer stairs, screens, external ceiling, retaining walls, debris resistant glazing, seismic restraints, decking, etc.)	Preliminary information showing design intent	Address comments from previous review  Elevations, sections, plans confirmed and presented  Construction type shown confirmed and presented	Address comments from previous reviews  Elevations, sections, layout plans and related details progressing and at an advanced stage	Address comments from previous reviews  All details complete	Address comments from previous reviews  Complete

## 5 Additional design requirements

Comply with the following additional specific requirements.

### 5.1 General design requirements

#### 5.1.1 Design engineer

The structural engineer responsible for the design and certification shall be a NT Registered Building Practitioner (Structural) with extensive experience and proven track record in design and construction for buildings commensurate with the value, usage and complexity of the proposed works.

Provide an efficient structural design and high-quality documentation.

Review reports and address any comments of the independent third party review engineer.

Provide the required Section 40 engineering certificate and documentation to enable the Building Certifier to issue a Permit to Build.

Completion of a technical specification section relevant to this discipline.

NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND  
REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES -  
STRUCTURAL REQUIREMENTS

## 5.1.2 Design life

The building design life for the primary structure (floor foundations, walls and structural framing and roof structure) is defined to be 50 years as per the requirements of the NCC, AS/NZS 1170.0 and AS 3600.

## 5.1.3 Building importance levels

The determination of building Importance Level (IL) shall be in accordance with the criteria of the NCC.

Listed below are some examples of building types and their Importance Levels:

### Importance Level 1

- Buildings with a low degree of hazard to human life and other property in the event of a building failure.
- Minor structures (failure not likely to endanger human life).
- Farm buildings.
- Isolated minor storage facilities.
- Minor temporary facilities.

### Importance Level 2

- Normal structures and structures (not falling into other levels) with medium consequence to human life and considerable economic consequences in the event of failure.
- Low rise residential construction.
- Buildings and facilities below the limits set for importance level 3.
- Buildings and facilities where less than 300 people can congregate in one area.
- Buildings and facilities with a primary school, a secondary school or day care facilities with a capacity lower than 250.
- Building and facilities with a capacity lower than 500 for colleges or adult educational facilities.
- Health care facilities with a capacity of up to 50 residents and not having surgery or emergency treatment facilities.
- Car parking buildings.
- Any occupancy with an occupant load lower than 5000.

### Importance Level 3

- Major structures (affecting crowds) with high consequence for loss of human life or very great economic, social or environmental consequences in the event of failure.
- Buildings and facilities where more than 300 people can congregate in one area.
- Buildings and facilities with a primary school, a secondary school or day care facilities with a capacity greater than 250.
- Building and facilities with a capacity greater than 500 for colleges or adult educational facilities.
- Health care facilities with a capacity of 50 or more residents but not having surgery or emergency treatment facilities.
- The “strengthened area” within an aged care building (as defined in the NCC).
- Jails and detention facilities.

NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND  
REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES -  
STRUCTURAL REQUIREMENTS

- Any occupancy with an occupant load greater than 5000.
- Power generating facilities, water treatment and waste water treatment facilities, any other public utilities not included in Importance Level 4.
- Buildings and facilities not included in Importance Level 4 containing hazardous materials capable of causing hazardous conditions that do not extend beyond property boundaries.

#### Importance Level 4

- Buildings and facilities designated as essential facilities.
- Buildings and facilities with special post disaster functions.
- Medical emergency or surgery facilities.
- Emergency service facilities: fire, rescue, police station and emergency vehicle garages.
- Utilities required as backup for buildings and facilities of Importance Level 4.
- Designated emergency shelters (excluding cyclone shelters).
- Designated emergency centres and ancillary facilities.
- Buildings and facilities containing hazardous materials capable of causing hazardous conditions that extend beyond property boundaries.

#### 5.1.4 Structural robustness

Comply with the requirements of AS/NZS 1170.0, the NCC and ABCB Structural Robustness Handbook.

A structure shall be designed and constructed so that it will not be damaged to an extent disproportionate to the original cause, by events such as fire, explosion, impact or consequences of human errors.

Low-rise concrete panel buildings (which are prone to progressive collapse) shall be provided with more than one means of lateral stability so that there is an alternative load path.

For example, a roof framing system relying on a single set of roof cross bracing (to transfer lateral loads) is not acceptable. A minimum of two sets of cross bracing to give an alternative load path is required.

#### 5.1.5 Deflection limits

Generally, deflection limits shall be as per AS/NZS 1170.0.

<b>Table – Deflection limits</b>			
<b>Item</b>	<b>Description</b>	<b>Applied Load</b>	<b>Criteria Adopted</b>
Roof supporting elements	Mid-span deflection	$G + \Psi I Q + W_s$  $G + W_s$	Span/300
Floors and floor supports	Mid-span deflection	$G + \Psi I Q$	Span/350 or 30mm  Span/500 (under blockwork walls / glazing)
Wall elements	Mid-height deflection	$W_s$	Height/250
Transfer structures	Mid-span deflection	$G + \Psi I Q$	Span/500

### 5.1.6 Non-structural parts and components

Non-structural parts and components, including architectural, mechanical, and electrical components, and their fastenings, shall be designed for horizontal and vertical earthquake forces as per the **Design of parts and components** section of AS 1170.4 for all non-domestic buildings. Refer to the respective discipline's Minimum Design Standard (MDS) for further instructions.

### 5.1.7 Modification to existing structure

A structural assessment of the existing structure by visual inspection and examination of the original/as-built drawings shall be undertaken to confirm the accuracy of the original drawings, assessment of the impacts on the overall structure and the effect on the localised area affected by the proposed modifications.

### 5.1.8 Ecological sustainable design (ESD)

The design shall consider and incorporate ESD requirements into the structure wherever possible. This includes, but is not limited to: consideration in the use of steel (structural steelwork or reinforcement) manufactured from high recycled steel content, and General Purpose Blend (GB) cement that contains manufactured by-product slag, or a concrete mix that contains fly ash.

## 5.2 Design loads

The design of the building structure (for stability, strength and serviceability) shall be capable of resisting the loads listed below:

- Design superimposed dead loads
- Design live loads
- Special design live loads in localised areas such as compactus storage
- Design wind loads
- Design earthquake loads
- Design bearing pressures for foundation material
- Any other relevant loadings

All design loads and their parameters relevant to the project shall be fully stated on drawings.

### 5.2.1 Dead and live loads

The dead loads shall be calculated in accordance with the principles of AS/NZS 1170.0 and AS/NZS 1170.1 and utilise a gravity constant of  $9.81\text{m/s}^2$ .

### 5.2.2 Wind loads

The wind loads shall be calculated in accordance with the principles of AS/NZS 1170.2.

### 5.2.3 Earthquake loads

The earthquake loads shall be calculated in accordance with the principles of AS 1170.4.

## 6 Geotechnical investigation

Prepare a written geotechnical investigation report of the site including any car parking areas.

The report shall provide information on subsurface conditions across the site, including but not limited to:

- Assessment of soil materials encountered across the site
- Site classification in accordance with AS 2870
- Recommendations on site preparation and earthworks requirements, including suitability of in-situ material for re-use as fill, placement of fill, compaction criteria and testing requirements
- Recommendations on suitable foundation systems
- Provide foundation design parameters, including allowable soil bearing pressures and estimated soil settlements
- Assessment of the site factor for earthquake design in accordance with AS 1170.4
- Assess pavement requirements and provide pavement subgrade design parameters, including CBR
- Provide comments on site drainage and groundwater
- Identify anticipated construction difficulties and provide possible solutions

The investigation shall be carried out by an experienced and qualified Geotechnical Engineer.

### 6.1 Foundation design

Foundation design shall be based on the recommendations of the Geotechnical Report prepared for the project. Fill material shall be select fill and compacting to 95% (min) MMDD. Depth of footings to be determined by Structural Engineer.

The project title, the name of the consultant / author, the report number, and the issue date of the Geotechnical Report shall be clearly noted on the drawings.

### 6.2 Earth pressure

Any designed structure, including retaining walls, shall be designed to resist earth pressures in accordance with the recommendations from the Geotechnical Investigation. Basement walls and floors must be protected via subsoil drains.

## 7 Building fabric and layout

### 7.1 Location of walls, columns and wall bracing

The design of the structure shall incorporate flexibility for future changes in internal layout or use. This requirement should be reflected in the design of the building structure. The use of internal walls as load bearing or structural walls is to be avoided where possible.

Careful consideration must be given to the location of columns within the building. Columns within the body of a functional space should be avoided wherever possible.

Walls required for bracing purposes should be carefully located so as not to impact severely on flexibility to rearrange the internal layout in the future.

### 7.2 Fire resistance

The structure and its component members shall be designed for the appropriate fire resistance in accordance with the requirements of the NCC and relevant Australian Standards.

### 7.3 Strength

The structure and its component members shall be designed such that their design strength exceeds the appropriate design actions in accordance with the requirements of the NCC and relevant Australian Standards.

### 7.4 Stability

The structure as a whole and its parts shall be designed to prevent instability due to overturning, uplift and sliding in accordance with the requirements of the NCC and relevant Australian Standards.

### 7.5 Serviceability

The structure and its component members shall be designed for serviceability by controlling or limiting deflection, lateral drift, cracking, and vibration in accordance with the relevant Australian Standards unless noted below.

## 7.6 Waterproofing and weatherproofing

The exterior building fabric shall be resistant to water penetration. The fabric shall not permit penetration of uncontrolled water when tested in accordance with AS 2047 under a water penetration resistance test pressure of 630 Pa.

Floors, walls and lift pits shall be fully tanked where below grade or subject to hydrostatic pressure.

## 8 Concrete and masonry

### 8.1 Concrete durability

All concrete elements of the structure shall be designed for durability in accordance with the requirements of AS 3600, the exposure classification of particular concrete surfaces shall be detailed below.

Item	Description	Value	Comment
<b>Concrete Durability</b>	Design life	50 years	-
	Concrete exposure classification	A2	Surfaces in interior environments / surfaces in contact with ground protected by damp proof membrane
		B1	Near coastal / surfaces in above-ground exterior environments (1km to 50km from coast or tidal estuaries)
		32MPa (f'c) minimum	Vehicle pavements in any location

### 8.2 Crack control

Reinforcement for crack control shall be provided at, or better than, the ratios stipulated in AS 3600. This requirement does not replace any requirement for reinforcement specified for structural integrity.

### 8.3 Post tensioned or precast concrete slab

The adoption of post tensioned or precast concrete system for slab or beam is not allowed without the approval of DIPL.

If post tensioned slabs are installed, the location of all tendons must be marked on the underside of the slab to ensure that any future core holes cut in the slab do not intersect any stressing cables.

## 8.4 Ground slab moisture barrier and bedding sand

All floor slabs on ground shall be placed on moisture barrier equivalent to 300 micron thick 'Fortecon' polythene membrane, turned up at the perimeter and with all joints and penetrations sealed.

Do not use or specify 200 or 300 µm termite barrier polymer sheet (e.g. HomeGuard or similar product) as moisture barrier or damp proof membrane.

Bedding sand shall be a naturally occurring material that has a high clay/fine silt content to ensure the material can hold its shape when used under concrete slabs. Do not specify or use manufactured quarry sand as bedding sand. This must be clearly noted on the drawings.

## 8.5 External slab

External slabs associated with buildings are to be documented as part of structural documentation. This includes slabs for under cover walkways, verandahs, carports, and path slabs linking between buildings.

Do not document external slabs of buildings as part of civil design documentation.

## 8.6 Slab joints

Slab joints whether for contraction, expansion, or construction must be considered and documented as part of structural documentation. All joint locations to be clearly shown on the slab plans.

Slabs with architectural significance and slabs with visible surfaces must be carefully designed to minimise cracking.

Do not document joint locations and details of building slabs as part of architectural or civil documentation.

## 8.7 Masonry

Drawings to specify clean out inspection holes at base course of all reinforced and core fill cores. Clean out all cores which are to be filled progressively as the work proceeds.

Drawings are required to show full elevations of all external and internal shear blockwork walls.

Window sills are required to be fixed to bond beam with galvanised N12 shear pins at 600mm centres and at each window mullion.

All external blockwork, wet area blockwork, blockwork below ground level, and for the first 3 base courses above finished floor level shall be constructed using mortar with a damp-proof admixture such as "Cementaid Calblack" or similar. This must be clearly noted on the drawings.



NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND  
REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES -  
STRUCTURAL REQUIREMENTS

All external blockwork walls shall be concrete filled all cores for non-domestic buildings.

The use of unreinforced blockwork or brick masonry walls is prohibited for non-domestic buildings.

Blockwork control joints shall be provided in walls to minimise the effects of linear shrinkage, temperature variations, creep, and subgrade movement. All joint locations to be clearly marked on slab plans and wall elevations.

## 9 Steel and metal

### 9.1 Protective coatings on steel

#### **Durability**

The steel protection system shall satisfy the requirement of very long term durability of 25 years to first major maintenance and be warranted for a minimum of 20 years. Name the Principal as the warrantee.

Coating damage caused by welding or flame cutting, or during handling, transport, or erection shall be reinstated in accordance with the provisions of AS/NZS 4680, Repair after galvanizing section.

Bases of all external structural steel columns must be coated with "Epireze 215", coated 100mm below slab level or top of base plate, and extend to 100mm above finished concrete slab or above concrete collar surface level at the steel.

External steel columns / stumps surrounded by natural ground shall be encased with a reinforced concrete collar. The collars must extend horizontally a minimum of 100mm from the steel. The collars must be sloped down away from the column and finish not less than 100mm above natural ground level at the highest ground level point adjacent to the concrete collar.

#### **Guide Notes**

The steel protective coating/s for the project is/are to be selected from the following Table with options of inorganic zinc silicate (IZS), hot dip galvanised (HDG), or polyurethane system. Following the identification of the building location and the finish required, select and specify the appropriate coating/s from the Table. The selection of coating is to be read in conjunction with the associated NOTES below the table.

Do not use other protective coatings without approval.

Coating required is HDG, IZS, or polyurethane system (subject to the building location and finish required by the design architect), for all structural steelwork.

NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND  
REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES -  
STRUCTURAL REQUIREMENTS

Table – Steel protective coating selection		
Building Location	Coating	Comment
Inland tropical (areas more than 0.5km from coast or estuary)	Hot dip galvanised (HDG) - As per Table 1 of AS/NZS 4680	Steelwork to be galvanised shall be prepared and pre-treated to the requirements of AS 1627.4 and hot dip galvanised in accordance with AS/NZS 2312.2, AS/NZS 4792, AS/NZS 4680, and with the Standard Specification for Hot Dip Galvanizing, published by the Galvanizers Association of Australia, accessible via <a href="https://gaa.com.au/standard-specification-for-hot-dip-galvanizing/">https://gaa.com.au/standard-specification-for-hot-dip-galvanizing/</a> .
	Inorganic zinc silicate (IZS) - 75 µm DFT (min)	All non-galvanised steelwork is to be blast cleaned to a class 2½ finish and primed with 75 microns inorganic zinc silicate. Top or finish coat to be as per architectural specification.
Marine (areas 0.5km from coast or less)	Polyurethane System, total DFT 325 µm - Consists of 75 µm IZS primer, 200 µm high build epoxy (2 pack) intermediate coat, and 50 µm polyurethane (2 pack) topcoat	Prepared and primed as above. Colour to be as per architectural specification.

**NOTES:**

1. For this Guide, durability is defined as the time elapsed before the first major maintenance (recoating) of a coating system becomes necessary, to arrest corrosion.
2. The objective is to achieve maximum durability compatible with the 50 years design life of the structural steelwork, or equal to the expected service life of the structure as defined in the Brief or NCC.
3. The design of the structure influences the choice of a protective coating. As a general rule, important, difficult to access, and complicated structures should be given long-life systems to reduce the amount of costly maintenance. More durable coating at the beginning is more sustainable and this will lead to cost saving in the long run with less or no recoating required (lower lifecycle cost).
4. Any components of the structure which are not accessible after assembly should be provided with a corrosion protection system that will remain effective for the service life of the structure. If this cannot be achieved by means of a protective coating system, other measures, such as manufacturing from corrosion-resistant material, designing for replacement, or specification of a corrosion allowance, should be taken.
5. IZS and HDG have been chosen as the preferred steel protective coating systems due to their proven performance, superior durability and less maintenance (lower frequency of recoating required) than other products. Both have been shown to have a very long life to first maintenance in most environments and often no maintenance will be required during the entire life of the project.
6. As a guide, colour or architectural paint coated finish steel shall have a protective coating of IZS. Buildings located within the tropical, arid and more than 0.5km from the coast or tidal estuaries shall be coated with IZS or HDG. Steel surfaces vulnerable to corrosion in the coastal fringe would require a polyurethane coating system. Coastal fringe includes areas up to 0.5km from the coast or tidal estuaries.

NON-CYCLONIC WIND REGION A (>100KM FROM THE COASTLINE) & INTERMEDIATE WIND  
REGION B (>50KM AND UP TO 100KM FROM THE COASTLINE) - BUILDINGS OR STRUCTURES -  
STRUCTURAL REQUIREMENTS

7. The coating systems apply to all structural steelworks of the project, including internal and external (exposed) located steel members. This standardised approach minimises confusion and errors in design and fabrication, easier for quality control in verification and inspection, and provides consistency among all DIPL projects.

8. Specifiers to nominate the coating systems suitable for the project based on the coating options and criteria from the Table as well as other criteria stated in this Guide.

9. For works associated with refurbishment of existing steelwork, minor and temporary structures, or if only a shorter working life is required, a cheaper, less durable system may be sufficient. However, this will need to be assessed on a case by case basis, and be subject to approval by DIPL.

10. For this Guide, the atmospheric corrosivity category has been assessed as C5 for the areas of Coastal fringes, Tropical Inland or C4 for the areas north of Tennant Creek and up to the Top End, and C3 for the arid areas south of Tennant Creek to Central Australia.

## 9.2 Dissimilar metals

Contact between dissimilar metals shall be avoided to prevent galvanic corrosion. Special attention is required to reliably achieve isolation between dissimilar metal surfaces using marine-grade stainless steel inert spacers or washers.

## 9.3 Steel stud wall frame

Structural stud frames of light gauge “C” sections shall be no less than 1.2mm BMT and must be fully detailed. Drawing details shall include, but not be limited to, full elevation of every wall frame, member section sizes, welding connection, galvanised hold-down bolt information, and specification of Alcor flashing between base of bottom plate and concrete.

Do not specify manufacturer proprietary systems.

Do not specify manufacturer to design, manufacture, and certify for structural stud wall frames.

## 9.4 Metal capping and flashing

All exposed parts of flashing and capping are to be screw fixed with No. 14 class 4 HH screws with EPDM seal. Fixing distances to be fully detailed and in accordance with AS 1562.1. This must be noted on the drawings.

## 9.5 Metal roof and wall sheeting

All metal sheeting to be Colorbond steel.

Sheeting thickness to be 0.48mm BMT minimum with Class 4 finish fixing screws.

Ceiling sheeting thickness can be 0.42mm BMT.

## 9.6 Hold-down anchor

All vertical hold-down anchors are to be cast-in system.